



PERFORMANCE EVALUATION TEST REPORT

Report No.: D6104.05-109-44

Rendered to:

ZILLA CORPORATION
Lafayette, Colorado

PRODUCT TYPE: Flashing Assembly

SERIES/MODEL: Zilla® Zip™, Zilla® Double Stud, Zilla® PVC Electrical, Zilla® Electrical XL, and Zilla® Double Stud XL

TEST METHOD: The test specimens were evaluated in accordance with AC 286, *Acceptance Criteria for Roof Flashing for Pipe Penetrations, Approved October 2012, Section 4.0* using the methodology of UL 441, *UL Standard for Safety for Gas Vents, Section 27: Rain Test*

Series/Model	UL 441 Rain Test Summary of Results	
	3/12 Pitch	12/12 Pitch
Zilla® Zip™ Flashing Assembly	Pass	Pass
Zilla® Double Stud Flashing with Mini Standoff	Pass	Pass
Zilla® PVC Electrical Flashing Assembly	Pass	Pass
Zilla® Electrical XL Flashing Assembly	Pass	Pass
Zilla® Double Stud XL	Pass	Pass

Test Date: 02/19/15
Report Date: 03/06/15